

# *Central Water Company*

## *Annual Drinking Water Quality Report*

### **INTRODUCTION**

This Annual Drinking Water Quality Report for calendar year 2008 is designed to provide you with valuable information about your drinking water quality. We are committed to providing you with a safe and dependable supply of drinking water, and we want you to understand the efforts we make to protect your water supply. The quality of your drinking water meets all state and federal requirements administered by the Virginia Department of Health (VDH). If you have questions about this report, want additional information about any aspect of your drinking water, or want to know how to participate in decisions that may affect the quality of your drinking water, please contact:

Mr. Stephen Rossi, Central Water Company, Inc. at (540) 342-6600
--

### **GENERAL INFORMATION**

As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and can pick up substances resulting from the presence of animals or from human activity. Substances (referred to as contaminants) in source water may come from septic systems, discharges from domestic or industrial wastewater treatment facilities, agricultural and farming activities, urban stormwater runoff, residential uses, and many other types of activities. Water from surface sources is treated to make it drinkable, while groundwater may or may not have any treatment.

All drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

### **SOURCES AND TREATMENT OF YOUR DRINKING WATER**

Your drinking water was groundwater obtained from one of three drilled wells. Two of the wells are located on the hill with the storage tank. The other well is located on an adjacent hill and is visible from the storage tank. Water is distributed throughout the system by the storage tank and distribution piping. Chlorination treatment is provided. A solution feed chlorinator blends chlorine solution with the well water before water enters the storage tank.

## **SOURCE WATER ASSESSMENTS**

A source water assessment has been completed by VDH. The assessment determined that the wells may be susceptible to contamination because they are located in an area that promotes migration of contaminants from land use activities of concern. More specific information may be obtained by contacting the water system representative listed above.

## **QUALITY OF YOUR DRINKING WATER**

Your drinking water is routinely monitored according to Federal and State Regulations for a variety of contaminants. The tables that follow show the results of our monitoring for the period of January 1<sup>st</sup> through December 31<sup>st</sup>, 2008.

Most of the results in the table are from testing done in 2008. However, the state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, is more than one year old.

## **DEFINITIONS**

In the table and elsewhere in this report you will find many terms and abbreviations you might not be familiar with. The following definitions are provided to help you better understand these terms:

*Non-detects (ND)* – lab analysis indicates that the contaminant is not present.

*Parts per million (ppm) or Milligrams per liter (mg/l)* – one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Parts per trillion (ppt) or Nanograms per liter (nanograms/l)* – one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

*Picocuries per liter (pCi/L)* – picocuries per liter is a measure of the radioactivity in water.

*Nephelometric Turbidity Unit (NTU)* – nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

*Action Level* – the concentration of a contaminant, which if exceeded, triggers treatment or other requirements which a water system must follow.

*Treatment Technique (TT)* – a required process intended to reduce the level of a contaminant in drinking water.

*Maximum Contaminant Level, or MCL* – the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal, or MCLG* – the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Variances and exemptions* – state or EPA permission not to meet an MCL or a treatment technique under certain conditions.

## WATER QUALITY RESULTS

### Microbiological

Contaminant	Unit of Measurement	MCLG	MCL	Level Found	Violation	Sample Date(s)	Typical Source of Contamination
total coliform bacteria	presence or absence	0	presence of coliform bacteria in >1 sample per month	0	no	monthly	naturally present in the environment

Total coliform bacteria are analyzed monthly.

### Lead and Copper – most recent monitoring period 2006.

Contaminant	Unit of Measurement	MCLG	MCL	90% Level	AL Exceeded	Samples > AL	Typical Source of Contamination
lead	ppb	0	AL = 15	<5	no	0	corrosion of household plumbing systems; erosion of natural deposits
copper	ppm	1.3	AL = 1.3	0.103	no	0	

Lead and copper are analyzed every three years.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Central Water Company Inc. is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### Inorganic Contaminants

Contaminant	Unit of Measurement	MCLG	MCL	Level Found	Violation	Sample Date(s)	Typical Source of Contamination
nitrate	ppm	10	10	--	no	--	runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Well 3				1.64		7/5/07	
Well 4				0.33		7/5/07	
Well 5				0.23		7/5/07	
fluoride	ppm	4	4	--	no	--	erosion of natural deposits; discharge from fertilizer and aluminum factories
Well 3				0.21		7/19/06	
Well 4				<0.20		7/11/07	
Well 5				<0.20		12/4/06	

Most inorganic contaminants are analyzed every three years – nitrate is analyzed every year.

### Radiological Contaminants

Contaminant	Unit of Measurement	MCLG	MCL	Level Found	Violation	Sample Date(s)	Typical Source of Contamination
gross alpha radiation Well 3 Well 4 Well 5	pCi/l	0	15	-- 1.8 1.5 1.5-3.9	no	-- 1/13/03 4/30/02 Quarterly --	erosion of natural deposits
gross beta radiation Well 3 Well 4 Well 5	pCi/l	0	50	-- 2.7 3.4 1.2-3.2	no	1/13/03 4/30/02 Quarterly	erosion of natural deposits
combined radium Well 4 Well 5	pCi/l	0	5	-- 0.3 1.1-1.4	no	-- 4/30/02 Quarterly	erosion of natural deposits

Radiological contaminants are every three years for well 3 and every six years for well 4, both beginning in 2010, and currently every three months for well 5.

### Volatile Organic Contaminants

Contaminant	Unit of Measurement	MCLG	MCL	Level Found	Violation	Sample Date(s)	Typical Source of Contamination
no volatile organic contaminants were found in any well						*7/19/05 **7/14/05 ***Quarterly	

Volatile organic contaminants are initially analyzed quarterly, then annually, and ultimately every three years.

\*Well 3 \*\*Well 4 \*\*\*Well 5

### Unregulated Contaminants

Contaminant	Unit of Measurement	MCLG	MCL	Level Found	Violation	Sample Date(s)	Typical Source of Contamination
no unregulated contaminants were found in any well						*7/19/05 **7/14/05 ***Quarterly	

Unregulated contaminants are initially analyzed quarterly, then annually, and ultimately every three years.

\*Well 3 \*\*Well 4 \*\*\*Well 5

**Organic Contaminants** – collected at point of maximum detention time in the distribution system.

Contaminant	Unit of Measurement	MCLG	MCL	Level Found	Violation	Date of Sample(s)	Typical Source of Contamination
total trihalomethanes	ppm	0	80	<1ppb	no	7/11/07	by-product of drinking water chlorination
total haloacetic acids	ppm	0	60	<2ppb	no	7/11/07	by-product of drinking water chlorination

\* Organic contaminants analyzed every three years.

We constantly monitor for various contaminants in the water supply to meet all regulatory requirements. The table lists only those contaminants that had some level of detection. Many other contaminants have been analyzed but were not present or were below the detection limits of the lab equipment.

Maximum Contaminant Levels (MCLs) are set at very stringent levels by the U.S. Environmental Protection Agency. In developing the standards, EPA assumes that the average adult drinks 2 liters of water each day throughout a 70-year life span. EPA generally sets MCLs at levels that will result in no adverse health effects for some contaminants or a one-in-ten-thousand to one-in-a-million chance of having the described health effect for other contaminants.

**VIOLATION INFORMATION**

**Water Quality Violations – None**

**Monitoring and Reporting Violations – None**

This Drinking Water Quality Report was prepared by the water company with the assistance of the Virginia Department of Health. Please call if you have questions.

Signature: \_\_\_\_\_

Date: \_\_\_\_\_